

# EC-Declaration of Conformity

for the

## Pressure Transmitter of the series 0605, 0610 and 0620

Herewith we declare that the pressure transmitter of the series 0605, 0610 and 0620 complies with the requirements of EC-rule 89/336/EWG and the alternations 92/31/EWG and 93/68/EWG in accordance of the EMC.

The pressure transmitters are electronic units which are used in extra-low voltage. It transforms the physical value of a pressure to a electrical signal (voltage: 0605 and 0610 / current: 0620). The pressure transmitter are maintenance-free. Because of its design and the extremely low power rate there exists no danger.

The Pressure Transmitters must be installed by authorised, qualified personnel only. Observe the applicable safety regulations, laid down by the regulatory bodies in the country of use. The relevant safety-rules must be observed.

### Conform to the following specifications:

- **Immunity:**  
EN 61000-6-2 8/02 Immunity of Industry areas  
with basic rules:  
EN 61000-4-2  
EN 61000-4-3+A1  
EN 61000-4-4  
EN 61000-4-5  
EN 61000-4-6
- **Emitted interference:**  
EN 61000-6-3 8/02 emitted interference for the residential area  
with basic rules:  
DIN EN 55011  
DIN EN 55022
- **Safety rules:**  
EN 61010-1 8/02 safety rules for electrical  
measuring-, control- and laboratory instruments

**SUCO Robert Scheuffele GmbH & Co. KG**


Keplerstraße 12 - 14  
D-74321 Bietigheim-Bissingen

Bietigheim-Bissingen, den 11th of December 2007

i.V.

  
Roland Katzler, Quality Manager

i.V.

  
Guido Hering, Technical Manager